

☆



* R 9 4 4 1 *

STEAM WORK SHEET

PART NUMBER - JDL5A1F

MODEL - JR DELUXE SOLENOID VALVE
KW - 1.5
VOLTS - 120
PHASE - 1
SAFETY - 100#
SET @ - 60#

REQUISITION # _____

QTY. 1

ISSUED 10/31/89

COMPLETED _____

NAT'L. BD. NO. 39435

U.L. NO. _____

SERIAL NO. 41173

BOILER JR DELUXE SOLENOID VALVE 1.5KW 120V 1PH 100# SAFETY SET AT 60#.

PIPING	SIZE	SCHEDULE	SPEC.	BOLTED/THREADED
STEAM PIPE	.25"	40 BRASS	B-43	THREADED
	.25"	COPPER TUBE		
	.032WALL	ALLOY 122	SB-75	COMPRESSION
WATER FEED	.5"	80	SA-106	THREADED
BLOWOFF	.5"	80	SA-106	THREADED

VALVES	SIZE	TYPE	MIN. RATING	QUANTITY
STEAM OUTLET	.25"	ANGLE	125	1
FILL VALVE	.5"	BALL	150	1
CHECK VALVE	.5"	SWING	125	1
BLOWOFF	.5"	BALL	150	1
GAUGE TEST	.25"	GLOBE	125	1

SAFETY VALVE - .5" 100# 423LB/HR CAPACITY

ELEMENT - QTY. 1 @ 1.5KW

ELECTRIC TEST:

VOLTS 120 ~~100~~ AMPS 12 ~~15~~ WATTS 1500 DATE 12/28/89

DIELECTRIC VOLTAGE WITHSTAND TEST: VOLTS 1500 BY MB

HYDROSTATIC TEST OF COMPLETED BOILER:

PSIG 100 BY MB DATE 12/28/89

OPTIONAL EQUIPMENT:

MODULE _____ OTHER _____

ASSEMBLED BY: Junior T. L. L. L. DATE 12/27/89

INSPECTED & APPROVED BY: RB DATE 12/28/89