

AA6E1F QC TEST SHEET

SET PRESSURE @ 40

DATE 2-17-95

TIME 1 HRS. 0 MIN

CUSTOMER:	REIMERS	VIGOR	GESSWEIN	ROSENTHAL
CONTROL CIRCUIT	LOAD CIRCUIT	KW	ELEMENTS	PHASE
120 VOLTS	240 VOLTS	6	QTY=2 @ 3 KW	1

GROUNDING-CONTINUITY TEST

IAW WITH U.L.

SAT ☒ UNSAT ☐ BY 112 DATE 2-17-95

(CORRECTED/RETEST BY DATE)

CORRECTIVE ACTION:

amps= 25

DIELECTRIC VOLTAGE-WITHSTAND TEST

IAW WITH U.L. 499

SAT ☒ UNSAT ☐ BY 112 DATE 2-17-95

(CORRECTED/RETEST BY DATE)

CORRECTIVE ACTION:

by [Signature] date 2/17/95

HYDROSTATIC TEST OF COMPLETED BOILER

PSIG = 100

by 112 date 2/17/95

OVERALL QUALITY CHECK LIST

- 1.) CHECK TIGHTNESS: 2.) ☒ YES ALL WARNING TAGS ARE USED AND IN THEIR CORRECT LOCATION.

- ☒ WIRE TERMINAL
☒ ELEMENT
☒ PANEL
☒ CONTROLS
☒ ALL PIPING
☒ ALL VALVES

* PIPING

VALVES

ITEM	* SIZE	SCH	SPEC.	THRD	SIZE	TYPE	RTG	PART #
STEAM	.375"	80	SA-106	THRD	.375"	GLOBE	125	03222
FEED	.50"	80	SA-106	THRD	.50"	BALL	200	02490
					.5"	SPRING	125	
FEED					*.375"	SOL.	100	
BLOWOFF	.50"	80	SA-106	THRD	.50"	BALL	200	02490
GAUGE	.25" X .03"		SB-75	COMP	.25"	GLOBE	125	

SAFETY VALVE: QTY=1 .50" 100 PSIG 423 LB/HR #02637

* VERIFICATION BY IN PROCESS MATERIAL MONITORING

NAT'L. BO. NO. 48076

CRN NO.

SERIAL NO. 49856

