



0004773

Page: 1

## Work Order Traveler

SCHEDULED START: 07/29/04

DUE DATE: 08/04/04

ITEM NUMBER: HL24C3B

DESCRIPTION: BOILER HLR 24KW 208V 3PH 30# S

REVISION: 000

OPTION CODE:

/ QUANTITY: 2.00

UNIT OF MEASUREMENT: EA

MAKE FOR: I/M

PLANNER:

RCBF 5 3/4

| STEP | QTY | PART     | DESCRIPTION                      | STEP | QTY | PART | DESCRIPTION |
|------|-----|----------|----------------------------------|------|-----|------|-------------|
| 0010 | 2   | 01483    | SWITCH 2P 2THR .25" SPADE CARL   |      |     |      |             |
| 0010 | 1   | 01904    | BRASS ROD .25" (WELDING ROD)     |      |     |      |             |
| 0010 | 4   | 02022    | FLANGE GASKET 2" RING            |      |     |      |             |
| 0010 | 2   | 02125    | FUSE 250V 15A UL/CSA             |      |     |      |             |
| 0010 | 12  | 02128    | FUSE 250V 50A UL/CSA ← 40A OK SH |      |     |      |             |
| 0010 | 4   | 02139A   | LIGHT 120V RED OMNI GLOW         |      |     |      |             |
| 0010 | 2   | 02140    | FUSE BLOCK 250V 30A 1P UL/CSA    |      |     |      |             |
| 0010 | 4   | 02142    | FUSE BLOCK 250V 60A 3P UL/CS     |      |     |      |             |
| 0010 | 4   | 02186    | ELEMENT 240V 15KW 3P SS SHEATH   |      |     |      |             |
| 0010 | 2   | 02205    | CEILING PLATE .75" I.P.S. FLAN   |      |     |      |             |
| 0010 | 4   | 02209SS  | WRAPPER END 20" 20103REV.B 16G   |      |     |      |             |
| 0010 | 2   | 02376    | TRANSFORMER 120/24V 45VA HONEY   |      |     |      |             |
| 0010 | 2   | 02378    | AQUASTAT L4008A1007 HW 100-240   |      |     |      |             |
| 0010 | 2   | 02384    | VALVE SAFETY .75" 30# HOTWATER   |      |     |      |             |
| 0010 | 4   | 02433    | AQUASTAT WELL .5"W/CLIP HW       |      |     |      |             |
| 0010 | 2   | 02445    | SWITCH CH SINGLE POLE DOUBLE T   |      |     |      |             |
| 0010 | 2   | 02514    | VALVE BALL .75" 200# SWP         |      |     |      |             |
| 0010 | 2   | 02526    | PROPORTIONAL CONTROL 80-210F     |      |     |      |             |
| 0010 | 4   | 02530    | CONTACTOR 50A 120V 3P UL/CSA     |      |     |      |             |
| 0010 | 2   | 02567    | THERMOMETER REMOTE MT 2.5"300F   |      |     |      |             |
| 0010 | 2   | 02569    | PRESSURE GAUGE 2.5" PANEL MOUN   |      |     |      |             |
| 0010 | 2   | 02599    | AQUASTAT L4008E 1040 HW HI LIM   |      |     |      |             |
| 0010 | 2   | 02616    | BLOCK POWER DISTRIBUTION 3-2/0   |      |     |      |             |
| 0010 | 2   | 02630    | ELECTRODE FITTING CAST WARRICK   |      |     |      |             |
| 0010 | 2   | 02680    | CONTACTOR 25A 24V 3P 8229A-100   |      |     |      |             |
| 0010 | 4   | 02992    | CEILING PLATE 1.25" O.D. FLANG   |      |     |      |             |
| 0010 | 2   | 03089    | CARTON 42W 54L 36.75 500# TEST   |      |     |      |             |
| 0010 | 2   | 03286    | TIMER SOCKET FOR OMRON (#H2C-8   |      |     |      |             |
| 0010 | 2   | 03465    | RELAY SOLID STATE CONTROL 120V   |      |     |      |             |
| 0010 | 2   | 03551    | SWITCH MANUAL RESET NC MO 14"L   |      |     |      |             |
| 0010 | 2   | 04097    | RELAY TIME DELAY 24 VAC          |      |     |      |             |
| 0010 | 2   | 20071    | GAUGE PLATE HLR 24-550           |      |     |      |             |
| 0010 | 2   | 20083A   | ELECTRICAL BOX 22W 24H 4D (SS)   |      |     |      |             |
| 0010 | 2   | 20153    | WRAPPER HLR 12-108               |      |     |      |             |
| 0010 | 2   | HLR-36   | SHELL HLR 24;30;36 (COMPLETE)    |      |     |      |             |
| 0010 | 2   | SKID2A   | SKID BOILER NEW R;RH;RHC 24-70   |      |     |      |             |
|      | 2   | 04316    | RELAY (NEW)                      |      |     |      |             |
|      | 2   | 20350-23 | BOX BRACE                        |      |     |      |             |