

CRN# _____

NATBLD# 60977 SERIAL# 62815

MODELRXHC36K3F
WIRE DIAG.....
WIRE SIZE.....10
HZ.....60
VOLTS.....480
CONTROL VOLT....120.
PHASE.....3
PRESSURE.....
KILOWATTS...36
CAPACITY 125 BPH/BTU/HR

OPERATIONAL TEST/ELECTRIC AND STEAM

UL FILE # E39545

DAY/MONTH 3 / 3 2005
VOLTS 480 AMPS 42.3 TOTAL WATTS 36,000
PRESSURE 50 DIFF 5

HEATER VOLTS 480KW 36PH 3 HZ 60

Reimers Electra Steam, 4407 Matrinsburg, Pike
Clear Brook, Va. 22624 PH 540-662-3811 FAX: 540-665-8101

APPEARANCE ☒
BLOWDOWN MAN — AUTO —
CONDENSATE TANK —
CONDENSATE & PIPE, ECT —
CONTROLS —
ELEMENT —
FEED HEATER VALVES —
INSTRUCTION BOOK —
LEAK INSPECTION —
PAINT —
PANEL —
PIPES —
PRESSURE CONTROLS —
SHEET METAL —
STEAM VALVE —
STEAM GAUGE —
STRANIER —
WARNING TAGS —
WATER GAUGE FITTINGS —
WIRE TERMINALS TIGHT —
WIRING DIA. —
ELEMENT QTY. 2
ELEMENT VOLT/KW 480V - 36KW
JURISDICTION = VA.
FUEL =ELECTRIC

TEAM

HOT WATER

MAX. W.P. 100 (NAMEPLATE)
MIN. SAFETY VALVE CAP. 126 PPH

MAX. W.P. _____ PSIG
MAX. TEMP. _____ DEG F
MIN. SAFETY VALVE CAP _____ PPH OR BTU
(3412 X KW/1000)

HYDRO TEST OF COMPLETE BOILER

P.S.I.G. 100 BY SB DATE 3/3/05
LOW WATER CUTOFF ✓ HI WATER CUTOFF ✓

SAFETY VALVE

CAPACITY 423
LB PER HR.

OPERATIONAL
TEST ✓

DIELECTRIC VOLTAGE- WITHSTAND TEST:

VOLTS 2352 SAT ✓ UNSAT _____ BY BSB DATE 3-3-05 (IAW U.L. 834)


(CORRECTED/RETEST) _____ BY _____ DATE _____ CORRECTIVE ACTION _____

NAMEPLATE: O.P. 100 KW 36 VOLTS 480 PH 3 HZ 60

Representing Reimers Electra Steam, INC. BY(Print) BRAD BUTTS DATE 3-3-05

Signature Brad Butts

INITIAL & DATE OPERATING CONTROLS, SAFETY CONTROLS, SAFETY VALVE ON REVERSE SIDE UPON COMPLETION OF OPERATIONAL TEST PERFORMANCE
(REF: ASME CSD-1, CG-500)



0005851

Page: 1

Work Order Traveler

SCHEDULED START: 02/28/05
DUE DATE: 03/01/05ITEM NUMBER: **RXHC36K3F**DESCRIPTION: **BOILER RHC 36KW 480V 3PH 100#**

REVISION: 000

OPTION CODE:

QUANTITY: **1.00**

UNIT OF MEASUREMENT: EA

MAKE FOR: I/M

PLANNER:

STEP	QTY	PART	DESCRIPTION	STEP	QTY	PART	DESCRIPTION
0010	2	01088	UNION .5" BLACK MALLEABLE IRON	0010	1	02522	GAUGE PROTECTOR 6"
0010	2	01094	ELBOW .5" X 90 DEG. BLACK MALL	0010	2	02530	CONTACTOR 50A 120V 3P UL/CSA
0010	2	01095	ELBOW .75" X 90 DEG. BLACK	0010	2	02613	FUSE BLOCK 600V 30A 3P UL/CSA
0010	1	01097	ELBOW 1.25" X 90 DEG. BLACK	0010	1	02616	BLOCK POWER DISTRIBUTION 3-20
0010	1	01101	ELBOW 1" X .5" REDUCING BLACK	0010	1	02637	VALVE SAFETY .5" 100# SWP 1" O
0010	2	01103	TEE .75" BLACK MALLEABLE IRON	0010	5	02766	NIPPLE .5" X CLOSE BLACK EH
0010	5	01104	TEE .5" BLACK MALLEABLE IRON	0010	3	02788	NIPPLE .5" X 2" BLACK EH ASTM
0010	1	01121	BUSHING 1" X .5" HEX	0010	1	02789	NIPPLE .5" X 2.5" BLACK EH
0010	1	01128	BUSHING .5X.25 HEX BLACK	0010	1	02791	NIPPLE .5" X 3.5" BLACK EH
0010	4	01133	ELBOW .5X90 DEG. STREET BLACK	0010	2	02796	NIPPLE .5" X 6" BLACK EH ASTM
0010	4	01147	PIPE PLUG .5" SQUARE HEAD FRGD	0010	2	02802	NIPPLE .75X4 BLACK EXHEAVY
0010	5	01160	NIPPLE .25XCLS.BRASS SCH40	0010	1	02807	NIPPLE .75" X 9" BLACK EH ASTM
0010	1	01162	ELBOW .25" BRASS FEMALE	0010	1	02810	NIPPLE 1" CLOSE BLACK EH ASTM
0010	8	01168	NUT .625"-11 HEAVY HEX STEEL	0010	1	02818	NIPPLE 1.25X2 BLACK EXHEAVY
0010	2	01180	NIPPLE .75" X CLOSE BLACK EH	0010	1	02820	NIPPLE 1.25X4 BLACK EXHEAVY
0010	1	01217	NIPPLE 1" X 4" BLACK EH ASTM	0010	2	02951	KNOCKOUT SEAL .5" HEYCO
0010	1	02012	VALVE GLOBE .75" 125#SWP H.WHL	0010	1	02988	CROSS .5" BLACK MALLEABLE IRON
0010	2	02022	FLANGE GASKET 2" RING	0010	2	02997	ELBOW STREET .25" 90 DEG.
0010	3	02099	SWITCH LOCK RING	0010	1	03021	COUPLING FULL .5" NPT 3000#
0010	1	02100	SWITCH CH SINGLE POLE SINGLE T	0010	1	03089	CARTON 42W 54L 36.75 500# TEST
0010	3	02107	SWITCH PLATE ON-OFF FOR TOGGLE	0010	1	03254	VALVE GAUGE TEST .25"
0010	1	02125	FUSE 250V 15A UL/CSA	0010	3	03760	COPPER TUBE REF.5"ODX.032WALL
0010	6	02134	FUSE 600V 30A UL/CSA	0010	1	03763	ELBOW .5" TUBE X .5" NPT NO NUT
0010	1	02139A	LIGHT 120V RED OMNI GLOW	0010	1	03802	VALVE BALL .75" W/LATCH 200# S
0010	1	02140	FUSE BLOCK 250V 30A 1P UL/CSA	0010	0	03818	TICKET HOLDER FOR SHOP CLEAR F
0010	6	02176	TERMINAL LUG #8 HOMAC UL/CSA	0010	1	03821	CONNECTOR .5" TUBE X .5" MALE NP
0010	2	02188	ELEMENT 480V 18KW 3P SS SHEATH	0010	1	04163	PRESSURE CONTROL 60# OPERATING
0010	1	02207	CEILING PLATE 1.25" PIPE SIZE	0010	2	04167	BUSHING .5" X .125" HEX
0010	2	02209SS	WRAPPER END 20" 20103 REV.B 16G	0010	1	04229	DECAL SHEET
0010	4	02240	CONDUIT .375" FLEXIBLE STEEL U	0010	1	04271	BUSHING 1.25" X .75" HEX BLACK
0010	2	02244	CONDUIT FLEXIBLE 1.25" U.L.	0010	0	04276	TERMINAL STRIP 600V 35 AMP 10-
0010	2	02246	CONDUIT CONNECTOR .375" 90 DEG	0010	1	04296	PRESSURE CONTROL 90# HI LIMIT
0010	2	02250	CONDUIT CONNECTOR 1.25" 90 DEG	0010	1	04391	LABEL NAMEPLATE UL/CSA 3.48 X
0010	2	02252	CONDUIT CONNECTOR .375" STR UL	0010	0	04308	TAPE ALUMINUM FOIL DUCT 50YD R
0010	1	02329	PRESSURE GAUGE 2.5" 160#MT23	0010	2	04400	SYPHON TUBE .25" BRASS ASTM SB
0010	1	02370	VALVE CHECK .5" 200# SWP	0010	10	04439	WIRE #18 TGGT 600V 250C UL/CSA
0010	1	02396	WATER GAUGE SET STANDARD SHANK	0010	2	04522	NIPPLE .5 X 1.5" BRASS
0010	1	02420	GAUGE GLASS 6" X .625" PYREX	0010	2	04523	TEE .5" BRASS ASTM B62 C836



0005851

Page: 2

Work Order Traveler

SCHEDULED START: 02/28/05
DUE DATE: 03/01/05ITEM NUMBER: **RXHC36K3F**DESCRIPTION: **BOILER RHC 36KW 480V 3PH 100#**

REVISION: 000

OPTION CODE:

QUANTITY: **1.00**

UNIT OF MEASUREMENT: EA

MAKE FOR: I/M

PLANNER:

STEP	QTY	PART	DESCRIPTION	STEP	QTY	PART	DESCRIPTION
0010	1	04525	CROSS .5" BRASS B62 C836				
0010	1	04526	NIPPLE .5" X 6" BRASS ASTM B43				
0010	2	04528	CABLE TIE MOUNT				
0010	2	04529	STANDOFF HEX 1.5" X .375" FOR				
0010	1	20054A	WRAPPER R24-80 (NEW)				
0010	1	20084B	ELECTRICAL ENCLOSURE 26" X 30"				
0010	1	20292-14A	ELECTRIC BOX SUPPORT 33" X 1.5				
0010	1	20350-7A	BRACE ELECTRICAL BOX SS (NEW)				
0010	1	20721	ELECTRONIC BOILER CONTROL (RB)				
0010	1	20739	PUMP ASSEMBLY (RHC 36-60)				
0010	1	20740	COND. TANK ASSY. (RHC 36-120)				
0010	1	20757	ELECTRICAL PNL ASSY R36-120 LE				
0010	1	MBJ-9	GAUGE GLASS SAFETY ROD R-MODEL				
0010	1	R-40A	SHELL R-40 (COMPLETE NEW)				
0010	1	SKID2A	SKID BOILER NEW R,RH,RHC 24-70				