

CRN#

NATBLD#

61011

SERIAL#

62819

ODELRB20K3F
TIRE DIAG.....WRB20K3F
TIRE SIZE.....12
Z.....60
OLTS.....480
ONTROL VOLT....120.
HASE.....3
RESSURE..... 40
LOWATTS.....20
APACITY 69 PPH/BTU/HR

OPERATIONAL TEST/ELECTRIC AND STEAM

UL FILE # E39545

DAY/MONTH 21 / 12 2004

TEST TIME: START _____ STOP _____

VOLTS 480 AMPS 23.5 TOTAL WATTS 20000PRESSURE 40 DIFF 5 LB. PER HR. 69HEATER VOLTS 480KW 20PH 3 HZ 60

Reimers Electra Steam, 4407 Matrinsburg, Pike

Clear Brook, Va. 22624 PH 540-662-3811 FAX: 540-665-8101

STEAM

HOT WATER

X. W.P. 100 PSIGN. SAFETY VALVE CAP. 70 PPH
(3.5 X KW)

MAX. W.P. _____ PSIG

MAX. TEMP. _____ DEG F

MIN. SAFETY VALVE CAP _____ PPH OR BTU
(3412 X KW/1000)

HYDRO TEST OF COMPLETE BOILER

S.I.G. 150 BY BA DATE 12/21/04
LOW WATER CUTOFF _____ HI WATER CUTOFF ✓

SAFETY VALVE

CAPACITY 423OPERATIONAL
TEST ✓

ELECTRIC VOLTAGE- WITHSTAND TEST:

VOLTS 2352 SAT ✓ UNSAT _____ BY BA DATE 12/21/04 (IAW U.L. 834)

CORRECTED/RETEST) _____ BY _____ DATE _____ CORRECTIVE ACTION _____

APPEARANCE ✓BLOWDOWN MAN ✓ AUTO ✓

CONDENSATE TANK _____

CONDENSATE & PIPE, ECT _____

CONTROLS _____

ELEMENT _____

FEED HEATER VALVES _____

INSTRUCTION BOOK _____

LEAK INSPECTION _____

PAINT _____

PANEL _____

PIPES _____

PRESSURE CONTROLS _____

SHEET METAL _____

STEAM VALVE _____

STEAM GAUGE _____

STRANIER _____

WARNING TAGS ✓WATER GAUGE FITTINGS ✓WIRE TERMINALS TIGHT ✓

WIRING DIA. _____

ELEMENT QTY. 2ELEMENT VOLT/KW 480V - 20KW

JURISDICTION = VA.

FUEL = ELECTRIC

NAMEPLATE: O.P. 100 KW 20 VOLTS 480 PH 3 HZ 60Representing Reimers Electra Steam, INC. BY (Print) William K. Hutton DATE 12/21/04Signature William K. Hutton

INITIAL & DATE OPERATING CONTROLS, SAFETY CONTROLS, SAFETY VALVE ON REVERSE SIDE UPON COMPLETION OF OPERATIONAL TEST PERFORMANCE
(REF: ASME CSD-1, CG-500)