

CRN# _____

NATBLD# 67476 SERIAL# 69391

OPERATIONAL TEST/ELECTRIC AND STEAM

UL FILE # E39545

MODELRB10E1F
DIAG.....
WIRE SIZE...8
HZ.....60
VOLTS.....240
CONTROL VOLT....120
PHASE...1
PRESSURE.....15
KILOWATTS...10
CAPACITY 34 PPH/BTU/HR

DAY/MONTH 12/5 20010
VOLTS 240 AMPS 41.0 TOTAL WATTS 10K
PRESSURE 15 DIFF 1

Reimers Electra Steam, 4407 Matrinsburg, Pike
Clear Brook, Va. 22624 PH 540-662-3811 FAX: 540-665-8101

HEATER VOLTS 240KW 10PH 1 HZ 60

APPEARANCE ☒
BLOWDOWN MAN ☒ AUTO ☐
CONDENSATE TANK ☐
CONDENSATE & PIPE, ECT ☐
CONTROLS ☒
ELEMENT ☒
FEED WATER VALVES ☒
INSTRUCTION BOOK ☒
LEAK INSPECTION ☒
PAINT ☒
PANEL ☒
PIPES ☒
PRESSURE CONTROLS ☒
SHEET METAL ☒
STEAM VALVE ☒
STEAM GAUGE ☒
STRANIER ☒
WARNING TAGS ☒
WATER GAUGE FITTINGS ☒
WIRE TERMINALS TIGHT ☒
WIRING DIA. ☒
ELEMENT QTY. 1
ELEMENT VOLT/KW 240 10
JURISDICTION = VA.
FUEL =ELECTRIC

STEAM

HOT WATER

MAX. W.P. 100 (NAMEPLATE)
MIN. SAFETY VALVE CAP. 35 PPH

MAX. W.P. _____ PSIG
MAX. TEMP. _____ DEG F
MIN. SAFETY VALVE CAP _____ PPH OR BTU
(3412 X KW/)

HYDRO TEST OF COMPLETE BOILER

P.S.I.G. 100 BY OC DATE 5/12/10
LOW WATER CUTOFF _____ HI WATER CUTOFF _____

DIELECTRIC VOLTAGE- WITHSTAND TEST:

VOLTS 1200 SAT ☒ UNSAT _____ BY OC DATE 5/12/10 (IAW U.L. 834)

(CORRECTED/RETEST) _____ BY _____ DATE _____ CORRECTIVE ACTION _____

SAFETY VALVE

CAPACITY 423
LB PER HR.

OPERATIONAL
TEST ☒

NAMEPLATE: O.P. 100 KW 10 VOLTS 240 PH 1 HZ 60

Representing Reimers Electra Steam, INC BY(Print) David E. Coffin DATE 5/12/10

Signature David E. Coffin

INITIAL & DATE OPERATING CONTROLS, SAFETY CONTROLS, SAFETY VALVE ON REVERSE SIDE UPON COMPLETION OF OPERATIONAL TEST PERFORMANCE
(REF: ASME CSD-1, CG-500)