

CRN# _____

NATL.BD# _____

7240 SERIAL# 74222

Reimers
Electra Steam, Inc.

4407 Martinsburg Pike

P: 540-662-3811

Clear Brook, VA 22624

F: 540-665-8101

www.reimersinc.com

sales@reimersinc.com

NAMEPLATE RATINGS:PART NUMBER RB20K3AMODEL R-20POWER SUPPLY WIRE SIZE 8POWER VOLTS 480CONTROL VOLT 120PHASE 3HZ 60MAX. W.P. 100KILOWATTS 20**CERTIFICATION & REPORTING (CG-500) CSD-1
OPERATIONAL TEST/ELECTRIC AND STEAM**DATE (M/D/Y) 12 / 30 / 20 14UL FILE # E39545WIRING DIAGRAM # 56, 91, 100, 110, 120, 131, 140 REV 5
X 160, 170, 180**DIELECTRIC VOLTAGE- WITHSTAND**

TEST: (IAW U.L. 834)

VOLTS 2350 SAT ☒ UNSAT ☐
PERFORMED BY OC DATE _____**HYDRO TEST OF
COMPLETE BOILER**P.S.I.G. 15
PERFORMED BY OC
DATE 12/30/14**HEATING ELEMENT TEST**VOLTS 480 AMPS 24.5TOTAL WATT 20K**CHECKOUT**

1. APPEARANCE ☒
2. BLOWDOWN MAN ☒ AUTO ☐
3. TRANSFORMER ☐
4. CONDENSATE TANK ☐
5. CONTROLS ☒
6. FEED WATER VALVES ☒
7. INSTRUCTION MANUAL ☒
8. LEAK INSPECTION ☒
9. PAINT ☒
10. PANEL ☒
11. PIPES ☒
12. SHEET METAL ☒
13. STEAM VALVE ☒
14. STEAM GAUGE ☒
15. STRAINER ☒
16. CHECK TORQUE ON TERMINAL STRIPS,
CONTACTORS AND FUSE BLOCKS ☒
17. WARNING LABELS ☒
18. WATER GAUGE FITTINGS ☒
19. WIRE TERMINALS TIGHT ☒
20. WIRING DIA. ☒
21. ELEMENT QTY. 2
22. ELEMENT VOLT/KW 480 10
23. NAMEPLATE ☒
24. JURISDICTION = VA
25. FUEL = ELECTRIC

SAFETY LIMIT CONTROLS (REF: ASME CSD-1, CG-500)**SAFETY RELIEF VALVE**OPERATIONAL TEST PERFORMED OCDATE 12/30/14MANUFACTURER CONBRACOModel # 19-KEDA-15BH**STEAM BOILER** ☒**HOT WATER BOILER** ☐MAX. W. P. 15 PSIG (VALVE ASME PLATE)

MAX. W. P. _____ PSIG (VALVE ASME PLATE)

CAPACITY 310 PPH (VALVE ASME PLATE)

CAPACITY _____ BTU/HR (VALVE ASME PLATE)

SIZE 3/4 IN

SIZE _____ IN

REQUIRED CAPACITY (PPH = 3.5 x kW) 70 PPH

REQUIRED CAPACITY (BTU/HR = 3412 x kW) _____ BTU/HR

MAX. TEMPERATURE _____ °F

	OPERATIONAL TEST	SETTING				
LOW WATER CUTOFF	PERFORMED BY	PSI/°F	DATE	MANUFACTURER	MODEL #	PART#
AUTO RESET	N/A	X				
MANUAL RESET	<u>OC</u>	X	<u>12/30/14</u>	REIMERS	04316	04316
PRESSURE CONTROLS						
HIGH LIMIT	<u>OC</u>	<u>15</u>	<u>12/30/14</u>	TECMARK	<u>3160-EP</u>	<u>05077</u>
OPERATING #1	<u>OC</u>	<u>8</u>	<u>12/30/14</u>	TECMARK	<u>3160-EQ</u>	<u>04162</u>
OPERATING #2	N/A					
TEMPERATURE CONTROLS						
HIGH LIMIT	N/A					
OPERATING CONTROL						

Representing Reimers Electra Steam, INC. (Name) Dale E CoffDATE 12/30/14 Signature Dale E Coff

Representing Installer Contractor (Name) _____

DATE _____ Signature _____



0030003

Page: 1

Work Order Traveler

SCHEDULED START: 12/16/14

DUE DATE: 12/17/14

QUANTITY: 1.00

UNIT OF MEASUREMENT: EA

0030003

ITEM NUMBER: **RB20K3A**DESCRIPTION: **BOILER RB 20KW 480V 3PH 15# SA**

REVISION: 003

OPTION CODE:

MAKE FOR: I/M

PLANNER:

QTY	PART	DESCRIPTION	QTY	PART	DESCRIPTION
1	20654	BRACKET SOLENOID VALVE	1	RB30-SUBAS	SUBASSEMBLY RB 10 THRU 30 BOIL
1	04462	BUSHING .375 X .25 BRASS SB16	6	04080	TERMINAL RING FOR # 8 AWG WIR
1	03944	BUSHING .5 X .375 BRASS (PARKE	6	02741	TERMINAL RING 10-12WIRE #10STU
-1	03945	BUSHING .75 X .5 BRASS (PARKER	1	03818	TICKET HOLDER FOR SHOP CLEAR F
1	04701	CARTON RB 30W 35L 28.75H SLOT	1	02490	VALVE BALL .5" 200# SWP
1	02254	CONNECTOR .375" 2 SCREW NEER	1	03346	VALVE BALL .5" W/LATCH 200 SWP
1	02530	CONTACTOR 50A 120V 3P UL/CSA	1	02010	VALVE SAFETY .75" 15# SWP 1" O
1	20838	CONTROLLER 04316-EBC-LED	1	04761	VALVE SOLENOID .375" 120V WATE
1	04786	COUPLING FULL .75" BRASS B 16.	10	04278	WIRE #10 TGGT PTFE INS. W/GLAS
1	20775-11	COVER ELEMENT TERMINALS RB REV	2	04789	WIRE SADDLE NYLON LOCKING
1	20775-7	COVER RIGHT ELEC BOX RB REV3			
1	04229	DECAL SHEET			
1	04813	DINCONNECTOR/CORD FOR RB BOILE			
1	03923	ELBOW .5" TUBE X .375" NPT SB			
2	04166	ELEMENT 480V 10KW 3P BDIM=18 Y			
-2	20598	FLANGE BLIND 2.5" SQ. 4 BOLT			
1	02655	FUSE 250V 5A UL/CSA			
-2	02281-TOPOG	GASKET 2.5"X .125"t TOPOG-E			
1	20862	LABEL MAX. TORQUE 40. LB IN /0			
1	20860	LABEL MAX. TORQUE 7.0 LB IN /0			
1	04301	LABEL NAMEPLATE UL/CSA 3.48 X			
2	03077	LOCKWASHER .25" STEEL HELICAL			
1	20840	MANIFOLD FEED WATER SUBASSY RB			
1	04668	NIPPLE .25" X 1.125" BRASS SCH			
2	03948	NIPPLE .375 X CLOSE BRASS (PAR			
-1	03949	NIPPLE .5 X CLOSE BRASS SCH 40			
1	04777	NIPPLE .75" X 2" BRASS ASTM B4			
1	04787	NUT .25-20 WING ZINC PLATED			
2	01351	NUT .25-20HEX JAM PLATE			
1	05077	PRESSURE CONTROL 13.5# HIGH LI			
1	04162	PRESSURE CONTROL 5# OPERATING			
1	20842	PRESSURE CONTROL MANIFOLD RB R			
1	02451	PRESSURE GAUGE 2.5" 0-30#			
1	20775-9	PUMP BASE MOUNTING BRACKET			
1	20775-8	PUMP BASE SOL VAL. RB REV3			
1	04593	SCREW .25-20 X .75 HEX CAP PLA			
1	04760	SCREW 1/4"-20 X .75" PAN HEAD			
8	01291	SCREW 8-32X.25RNDHD SLT MCH ZI			
10	01246	SCREW 8-32X.375RDHD MCH PLT SL			
-2	04811	SPRING DISC .328" ID X .687" O			
1	03262	STRAINER .375" Y SB-584 C844			
1	04731	STUD PRESS-IN THREADED .25"-20			