

CRN# _____

NATL.BD# 72731SERIAL# 74718**Reimers**
Electra Steam, Inc.4407 Martinsburg Pike
Clear Brook, VA 22624
www.reimersinc.comP: 540-662-3811
F: 540-665-8101
sales@reimersinc.com**NAMEPLATE RATINGS:**PART NUMBER RBH20K3F
MODEL RH-20
POWER SUPPLY WIRE SIZE 8
POWER VOLTS 480
CONTROL VOLT 120
PHASE 3
HZ 60
MAX. W.P. 100
KILOWATTS 20**CERTIFICATION & REPORTING (CG-500) CSD-1
OPERATIONAL TEST/ELECTRIC AND STEAM**DATE (M/D/Y) 6/12/2015UL FILE # E39545WIRING DIAGRAM # _____ REV 5**DIELECTRIC VOLTAGE- WITHSTAND**

TEST: (IAW U.L. 834)

VOLTS 2300 SAT ✓ UNSAT _____
PERFORMED BY OC DATE 6/12/15**HYDRO TEST OF
COMPLETE BOILER**P.S.I.G. 100
PERFORMED BY OC
DATE 6/12/15**HEATING ELEMENT TEST**VOLTS 480 AMPS 24.4TOTAL WATT 20K**CHECKOUT**

1. APPEARANCE ✓
2. BLOWDOWN MAN ✓ AUTO _____
3. TRANSFORMER _____
4. CONDENSATE TANK _____
5. CONTROLS ✓
6. FEED WATER VALVES ✓
7. INSTRUCTION MANUAL ✓
8. LEAK INSPECTION ✓
9. PAINT ✓
10. PANEL ✓
11. PIPES ✓
12. SHEET METAL ✓
13. STEAM VALVE ✓
14. STEAM GAUGE ✓
15. STRAINER ✓
16. CHECK TORQUE ON TERMINAL STRIPS,
CONTACTORS AND FUSE BLOCKS ✓
17. WARNING LABELS ✓
18. WATER GAUGE FITTINGS ✓
19. WIRE TERMINALS TIGHT ✓
20. WIRING DIA. ✓
21. ELEMENT QTY. 2
22. ELEMENT VOLT/KW 480 10
23. NAMEPLATE ✓
24. JURISDICTION = VA
25. FUEL = ELECTRIC

SAFETY LIMIT CONTROLS (REF: ASME CSD-1, CG-500)**SAFETY RELIEF VALVE**OPERATIONAL TEST PERFORMED DCDATE 6/12/15MANUFACTURER CONBRACOModel # 29-202A-100**STEAM BOILER** ☒**HOT WATER BOILER** ☐MAX. W. P. 100 PSIG (VALVE ASME PLATE)

MAX. W. P. _____ PSIG (VALVE ASME PLATE)

CAPACITY 423 PPH (VALVE ASME PLATE)

CAPACITY _____ BTU/HR (VALVE ASME PLATE)

SIZE 1/2 IN

SIZE _____ IN

REQUIRED CAPACITY (PPH = 3.5 x kW) 105 PPH

REQUIRED CAPACITY (BTU/HR = 3412 x kW) _____ BTU/HR

MAX. TEMPERATURE _____ °F

	OPERATIONAL TEST	SETTING				
LOW WATER CUTOFF	PERFORMED BY	PSI/°F	DATE	MANUFACTURER	MODEL #	PART#
AUTO RESET	<u>N/A</u>	<u>X</u>	<u>6/12/15</u>	<u>REIMERS</u>	<u>04316</u>	<u>04316</u>
MANUAL RESET	<u>OC</u>	<u>X</u>	<u>6/12/15</u>	<u>TECMARK</u>	<u>3155-ED</u>	<u>04296</u>
PRESSURE CONTROLS				<u>TECMARK</u>	<u>3156-EC</u>	<u>04163</u>
HIGH LIMIT	<u>OC</u>	<u>90</u>	<u>6/12/15</u>			
OPERATING #1	<u>OC</u>	<u>60</u>	<u>6/12/15</u>			
OPERATING #2	<u>N/A</u>					
TEMPERATURE CONTROLS						
HIGH LIMIT	<u>N/A</u>					
OPERATING CONTROL						

Representing Reimers Electra Steam, INC. (Name) Douglas E. CobbDATE 6/12/15 Signature Douglas E. Cobb

Representing Installer Contractor (Name) _____

DATE _____ Signature _____



0031493

Page: 1

Work Order Traveler

SCHEDULED START: 06/02/15

DUE DATE: 06/03/15

QUANTITY: 1.00

UNIT OF MEASUREMENT: EA

0031493

ITEM NUMBER: RBH20K3F

DESCRIPTION: BOILER RBH 20KW 480V 3 PH 100#

REVISION: 003

OPTION CODE:

MAKE FOR: I/M

PLANNER:

QTY	PART	DESCRIPTION	QTY	PART	DESCRIPTION
1	04701	CARTON RB 30W 35L 28.75H SLOT	1	02637	VALVE SAFETY .5" 100# SWP 1" O
1	02254	CONNECTOR .375" 2 SCREW NEER	10	04278	WIRE #10 TGGT PTFE INS. W/GLAS
1	02530	CONTACTOR 50A 120V 3P UL/CSA	2	04789	WIRE SADDLE NYLON LOCKING
1	20838	CONTROLLER 04316-EBC-LED			
1	04781	COUPLING .5" BRASS B16.15 125			
1	20775-11	COVER ELEMENT TERMINALS RB REV			
1	20775-7	COVER RIGHT ELEC BOX RB REV3			
1	04229	DECAL SHEET			
1	04813	DINCONNECTOR/CORD FOR RB BOILE			
1	20847	DISC, ORF-20 20KW STEAM ORIFIC			
1	03923	ELBOW .5" TUBE X .375" NPT SB			
2	04166	ELEMENT 480V 10KW 3P BDIM=18 Y			
-2	20598	FLANGE BLIND 2.5" SQ. 4 BOLT			
1	02655	FUSE 250V 5A UL/CSA			
-2	02281-TOPOG	GASKET 2.5" X .125" TOPOG-E			
1	20862	LABEL MAX. TORQUE 40. LB IN /0			
1	20860	LABEL MAX. TORQUE 7.0 LB IN /0			
1	04301	LABEL NAMEPLATE UL/CSA 3.48 X			
2	03077	LOCKWASHER .25" STEEL HELICAL			
1	20840	MANIFOLD FEED WATER SUBASSY RB			
1	04668	NIPPLE .25" X 1.125" BRASS SCH			
1	04787	NUT .25-20 WING ZINC PLATED			
2	01351	NUT .25-20HEX JAM PLATE			
2	04163	PRESSURE CONTROL 60# OPERATING			
1	04296	PRESSURE CONTROL 90# HI LIMIT			
1	20842	PRESSURE CONTROL MANIFOLD RB R			
1	04661	PRESSURE GAUGE 2.0" .25" 0-160			
1	20775-9	PUMP BASE MOUNTING BRACKET			
1	20992	PUMP SUBASSY 03693 120V 1 PH			
1	03344	RECEPTACLE CONN. MALE "AMPHENO			
1	03345	RECEPTACLE FEMALE "AMPHENOL"			
1	04593	SCREW .25-20 X .75 HEX CAP PLA			
1	04760	SCREW 1/4"-20 X .75" PAN HEAD			
8	01291	SCREW 8-32X.25RDHD SLT MCH ZI			
6	01246	SCREW 8-32X.375RDHD MCH PLT SL			
1	04731	STUD PRESS-IN THREADED .25"-20			
1	RB30-SUBAS	SUBASSEMBLY RB 10 THRU 30 BOIL			
6	04080	TERMINAL RING FOR # 8 AWG WIR			
6	02741	TERMINAL RING 10-12WIRE #10STU			
1	03818	TICKET HOLDER FOR SHOP CLEAR F			
1	02490	VALVE BALL .5" 200# SWP			
1	03346	VALVE BALL .5" W/LATCH 200 SWP			