

CRN# _____

NATL.BD# _____

SERIAL# _____

Reimers
Electra Steam, Inc.4407 Martinsburg Pike
Clear Brook, VA 22624
www.reimersinc.comP: 540-662-3811
F: 540-665-8101
sales@reimersinc.com

NAMEPLATE RATINGS:

PART NUMBER RBH10J3F
MODEL RH-10
POWER SUPPLY WIRE SIZE _____
POWER VOLTS 415
CONTROL VOLT 220
PHASE 3
HZ 50
MAX. W.P. 100
KILOWATTS 10CERTIFICATION & REPORTING (CG-500) CSD-1
OPERATIONAL TEST/ELECTRIC AND STEAMDATE (M/D/Y) 6/1/2015UL FILE # E39545WIRING DIAGRAM # 43, 91, 101, 113, 120, 131, 140 REV 5
X 160, 170, 180

DIELECTRIC VOLTAGE- WITHSTAND

TEST: (IAW U.L. 834)

VOLTS 250 SAT ✓ UNSAT _____
PERFORMED BY OC DATE 6/1/15HYDRO TEST OF
COMPLETE BOILERP.S.I.G. 100
PERFORMED BY OC
DATE 6/1/15

HEATING ELEMENT TEST

VOLTS 415 AMPS 8.2
TOTAL WATT 10K Amps tested on 240V

CHECKOUT

1. APPEARANCE ✓
2. BLOWDOWN MAN ✓ AUTO _____
3. TRANSFORMER ✓
4. CONDENSATE TANK _____
5. CONTROLS ✓
6. FEED WATER VALVES ✓
7. INSTRUCTION MANUAL ✓
8. LEAK INSPECTION ✓
9. PAINT ✓
10. PANEL ✓
11. PIPES ✓
12. SHEET METAL ✓
13. STEAM VALVE ✓
14. STEAM GAUGE ✓
15. STRAINER ✓
16. CHECK TORQUE ON TERMINAL STRIPS,
CONTACTORS AND FUSE BLOCKS ✓
17. WARNING LABELS ✓
18. WATER GAUGE FITTINGS ✓
19. WIRE TERMINALS TIGHT ✓
20. WIRING DIA. ✓
21. ELEMENT QTY. 1
22. ELEMENT VOLT/KW 240/10
23. NAMEPLATE ✓
24. JURISDICTION = VA
25. FUEL = ELECTRIC

SAFETY LIMIT CONTROLS (REF: ASME CSD-1, CG-500)

SAFETY RELIEF VALVE

OPERATIONAL TEST PERFORMED _____

DATE 6/1/15MANUFACTURER CONBRACOModel # 29-202A-100STEAM BOILER ☒HOT WATER BOILER ☐MAX. W. P. 100 PSIG (VALVE ASME PLATE)

MAX. W. P. _____ PSIG (VALVE ASME PLATE)

CAPACITY 423 PPH (VALVE ASME PLATE)

CAPACITY _____ BTU/HR (VALVE ASME PLATE)

SIZE 1/2 IN

SIZE _____ IN

REQUIRED CAPACITY (PPH = 3.5 x kW) 35 PPH

REQUIRED CAPACITY (BTU/HR = 3412 x kW) _____ BTU/HR

MAX. TEMPERATURE _____ °F

OPERATIONAL TEST		SETTING	DATE	MANUFACTURER	MODEL #	PART#
LOW WATER CUTOFF	PERFORMED BY	PSI/°F				
AUTO RESET	N/A	X				
MANUAL RESET	<u>OC</u>	X	<u>6/1/15</u>	REIMERS	04316	04316
PRESSURE CONTROLS						
HIGH LIMIT	<u>OC</u>	90	<u>6/1/15</u>	TECMARK	3155-ED	04296
OPERATING #1	<u>OC</u>	60	<u>6/1/15</u>	TECMARK	3156-EC	04163
OPERATING #2	N/A			TECMARK	3156-EC	04163
TEMPERATURE CONTROLS						
HIGH LIMIT	N/A					
OPERATING CONTROL						

Representing Reimers Electra Steam, INC. (Name) Daniel E. Coffey

Representing Installer Contractor (Name) _____

DATE 6/1/15Signature D. E. Coffey

DATE _____

Signature _____



0031368

Page: 1

Work Order Traveler

SCHEDULED START: 05/25/15

0031368

DUE DATE: 05/26/15

ITEM NUMBER: **RBJH10J3F**QUANTITY: **1.00**DESCRIPTION: **BOILER RBH 10KW 415V 3 PH 100#**

UNIT OF MEASUREMENT: EA

REVISION: 003

OPTION CODE:

MAKE FOR: I/M

PLANNER:

QTY	PART	DESCRIPTION	QTY	PART	DESCRIPTION
1	01776	BOX 4 X 2.125 X 1.875 STEEL CI	1	04700-HT	SKID 30" X 35.5" -HT RB rev3 H
1	01774	BOX COVER SINGLE OUTLET STEEL	-1	04700	SKID 30" X 35.5" RB rev3
1	04701	CARTON RB 30W 35L 28.75H SLOT	1	20845	STEAM SOLENOID VALVE MODULE 2
2	02240	CONDUIT ALFLEX type SWA .375"	1	04731	STUD PRESS-IN THREADED .25"-20
3	02246	CONDUIT CONNECTOR .375" 90 DEG	1	RB30-SUBASSY	SUBASSEMBLY RB 10 THRU 30 BOIL
1	03844	CONDUIT CONNECTOR .375" DUPLEX	6	04080	TERMINAL RING FOR # 8 AWG WIR
4	02266	CONDUIT SLEEVE .375" REDEYE	1	03818	TICKET HOLDER FOR SHOP CLEAR F
1	02530	CONTACTOR 50A 120V 3P UL/CSA	1	02475	TRANSFORMER .25KVA B WALL MT48
1	20838	CONTROLLER 04316-EBC-LED	1	02490	VALVE BALL .5" 200# SWP
1	04781	COUPLING .5" BRASS B16.15 125	1	03346	VALVE BALL .5" W/LATCH 200 SWP
1	20775-11	COVER ELEMENT TERMINALS RB REV	1	02637	VALVE SAFETY .5" 100# SWP 1" O
1	20775-7	COVER RIGHT ELEC BOX RB REV3	10	04440	WIRE #8 PTFE INS. W/GLASS SLEE
1	04229	DECAL SHEET	2	04789	WIRE SADDLE NYLON LOCKING
1	04813	DINCONNECTOR/CORD FOR RB BOILE			
1	03923	ELBOW .5" TUBE X .375" NPT SB			
1	04165	ELEMENT 240V 10KW 3PH B-DIM.=1			
-1	20598	FLANGE BLIND 2.5" SQ 4 BOLT			
2	04574	FUSE 250V 3 AMP UL/CSA			
-1	02655	FUSE 250V 5A UL/CSA			
-1	02281-TOPOG	GASKET 2.5"X .125" TOPOG-E			
1	20862	LABEL MAX. TORQUE 40. LB IN /0			
1	20860	LABEL MAX. TORQUE 7.0 LB IN /0			
1	04301	LABEL NAMEPLATE UL/CSA 3.48 X			
2	03077	LOCKWASHER .25" STEEL HELICAL			
1	20840	MANIFOLD FEED WATER SUBASSY RB			
1	04668	NIPPLE .25" X 1.125" BRASS SCH			
1	04787	NUT .25-20 WING ZINC PLATED			
2	01351	NUT .25-20HEX JAM PLATE			
2	04163	PRESSURE CONTROL 60# OPERATING			
1	04296	PRESSURE CONTROL 90# HI LIMIT			
1	20842	PRESSURE CONTROL MANIFOLD RB R			
1	04661	PRESSURE GAUGE 2.0" .25" 0-160			
1	20775-9	PUMP BASE MOUNTING BRACKET			
1	20992	PUMP SUBASSY 03693 120V 1 PH			
1	03344	RECEPTACLE CONN. MALE "AMPHENO			
1	03345	RECEPTACLE FEMALE "AMPHENOL"			
1	21020	RECEPTACLE OUTLET ADAPTER PLAT			
1	04184	RECEPTACLE OUTLET PANEL MOUNT			
1	04593	SCREW .25-20 X .75 HEX CAP PLA			
5	01268	SCREW 5-40 X .25 PANHD MACH PL			
8	01291	SCREW 8-32X.25RDHD SLT MCH ZI			
6	01246	SCREW 8-32X.375RDHD MCH PLT SL			