

CRN# _____

NATL.BD# 72734SERIAL# 74721

4407 Martinsburg Pike P: 540-662-3811
 Clear Brook, VA 22624 F: 540-665-8101
 www.reimersinc.com sales@reimersinc.com

NAMEPLATE RATINGS:

PART NUMBER RBH30K3F
 MODEL RH-30
 POWER SUPPLY WIRE SIZE 8
 POWER VOLTS 480
 CONTROL VOLT 120
 PHASE 3
 HZ 60
 MAX. W.P. 100
 KILOWATTS 30

CERTIFICATION & REPORTING (CG-500) CSD-1 OPERATIONAL TEST/ELECTRIC AND STEAM

DATE (M/D/Y) 5/28/2015UL FILE # E39545WIRING DIAGRAM # 58, 91, 101, 112, 120, 131, 140, X 160, 170, 180 REV 5

DIELECTRIC VOLTAGE- WITHSTAND TEST: (IAW U.L. 834)

VOLTS 2350 SAT ☒ UNSAT ☐
 PERFORMED BY DC DATE 5/28/15

HYDRO TEST OF COMPLETE BOILER

P.S.I.G. 100
 PERFORMED BY DC
 DATE 5/28/15

HEATING ELEMENT TEST

VOLTS 480 AMPS 36.1
 TOTAL WATT 30K

CHECKOUT

1. APPEARANCE ☒
2. BLOWDOWN MAN ☒ AUTO ☐
3. TRANSFORMER ☒
4. CONDENSATE TANK ☐
5. CONTROLS ☒
6. FEED WATER VALVES ☒
7. INSTRUCTION MANUAL ☒
8. LEAK INSPECTION ☒
9. PAINT ☒
10. PANEL ☒
11. PIPES ☒
12. SHEET METAL ☒
13. STEAM VALVE ☒
14. STEAM GAUGE ☒
15. STRAINER ☒
16. CHECK TORQUE ON TERMINAL STRIPS, CONTACTORS AND FUSE BLOCKS ☒
17. WARNING LABELS ☒
18. WATER GAUGE FITTINGS ☒
19. WIRE TERMINALS TIGHT ☒
20. WIRING DIA. ☒
21. ELEMENT QTY. 2
22. ELEMENT VOLT/KW 480 15
23. NAMEPLATE ☒
24. JURISDICTION = VA
25. FUEL = ELECTRIC

SAFETY LIMIT CONTROLS (REF: ASME CSD-1, CG-500)

SAFETY RELIEF VALVE

OPERATIONAL TEST PERFORMED DCDATE 5/28/15MANUFACTURER CONBRACOModel # 29-202A-100STEAM BOILER ☒HOT WATER BOILER ☐MAX. W. P. 100 PSIG (VALVE ASME PLATE)

MAX. W. P. _____ PSIG (VALVE ASME PLATE)

CAPACITY 423 PPH (VALVE ASME PLATE)

CAPACITY _____ BTU/HR (VALVE ASME PLATE)

SIZE 1/2 IN

SIZE _____ IN

REQUIRED CAPACITY (PPH = 3.5 x kW) 105 PPH

REQUIRED CAPACITY (BTU/HR = 3412 x kW) _____ BTU/HR

MAX. TEMPERATURE _____ °F

OPERATIONAL TEST	SETTING	DATE	MANUFACTURER	MODEL #	PART#
LOW WATER CUTOFF	PERFORMED BY	PSI/°F			
AUTO RESET	N/A	X			
MANUAL RESET	<u>DC</u>	X	<u>5/28/15</u>	REIMERS	04316
PRESSURE CONTROLS					
HIGH LIMIT	<u>DC</u>	90	<u>5/28/15</u>	TECMARK	3155-ED
OPERATING #1	<u>DC</u>	60	<u>5/28/15</u>	TECMARK	3156-EC
OPERATING #2	N/A				
TEMPERATURE CONTROLS					
HIGH LIMIT	N/A				
OPERATING CONTROL					

Representing Reimers Electra Steam, INC. (Name) David E. RothDATE 5/28/15 Signature [Signature]

Representing Installer Contractor (Name) _____

DATE _____ Signature _____

20f2



0031247

Page: 1

Work Order Traveler

SCHEDULED START: 05/18/15

0031247

DUE DATE: 05/20/15

ITEM NUMBER: **RBH30K3F**QUANTITY: ~~2.00~~ 1.00DESCRIPTION: **BOILER RBH 30KW 480V 3PH 100#**

UNIT OF MEASUREMENT: EA

REVISION: 003

OPTION CODE:

MAKE FOR: I/M

PLANNER:

QTY	PART	DESCRIPTION	QTY	PART	DESCRIPTION
2	04701	CARTON RB 30W 35L 28.75H SLOT			
2	02254	CONNECTOR .375" 2 SCREW NEER			
2	02530	CONTACTOR 50A 120V 3P UL/CSA			
2	20838	CONTROLLER 04316-EBC-LED			
2	04781	COUPLING .5" BRASS B16.15 125			
2	20775-11	COVER ELEMENT TERMINALS RB REV			
2	20775-7	COVER RIGHT ELEC BOX RB REV3			
2	04229	DECAL SHEET			
2	04813	DINCONNECTOR/CORD FOR RB BOILE			
2	03923	ELBOW .5" TUBE X .375" NPT SB			
4	04666	ELEMENT 480V 15KW 3P BDIM 18.5			
-4	20598	FLANGE BLIND 2.5" SQ. 4 BOLT			
2	02655	FUSE 250V 5A UL/CSA			
-4	02281-TOPOG	GASKET 2.5"X .125"t TOPOG-E			
2	20862	LABEL MAX. TORQUE 40. LB IN /0			
2	20860	LABEL MAX. TORQUE 7.0 LB IN /0			
2	04301	LABEL NAMEPLATE UL/CSA 3.48 X			
4	03077	LOCKWASHER .25" STEEL HELICAL			
2	20840	MANIFOLD FEED WATER SUBASSY RB			
2	04668	NIPPLE .25" X 1.125" BRASS SCH			
2	04787	NUT .25-20 WING ZINC PLATED			
4	01351	NUT .25-20HEX JAM PLATE			
2	04163	PRESSURE CONTROL 60# OPERATING			
2	04296	PRESSURE CONTROL 90# HI LIMIT			
2	20842	PRESSURE CONTROL MANIFOLD RB R			
2	04661	PRESSURE GAUGE 2.0" .25" 0-160			
2	20775-9	PUMP BASE MOUNTING BRACKET			
2	20992	PUMP SUBASSY 03693 120V 1 PH			
2	04593	SCREW .25-20 X .75 HEX CAP PLA			
2	04760	SCREW 1/4"-20 X .75" PAN HEAD			
16	01291	SCREW 8-32X.25RNDHD SLT MCH ZI			
12	01246	SCREW 8-32X.375RDHD MCH PLT SL			
2	04731	STUD PRESS-IN THREADED .25"-20			
2	RB30-SUBASY	SUBASSEMBLY RB 10 THRU 30 BOIL			
12	04080	TERMINAL RING FOR #8 AWG WIR			
12	02741	TERMINAL RING 10-12WIRE #10STU			
2	03818	TICKET HOLDER FOR SHOP CLEAR F			
2	02490	VALVE BALL .5" 200# SWP			
2	03346	VALVE BALL .5" W/LATCH 200 SWP			
2	02637	VALVE SAFETY .5" 100# SWP 1" O			
20	04278	WIRE #10 TGGT PTFE INS. W/GLAS			
4	04789	WIRE SADDLE NYLON LOCKING			

OPT1019-NH

OPT1009-480RBH

OC 5/28/15
OC 5/28/15

OC 5/28/15