

CRN# _____

NATL.BD# 72857SERIAL# 74 844**Reimers**
Electra Steam, Inc.4407 Martinsburg Pike
Clear Brook, VA 22624
www.reimersinc.comP: 540-662-3811
F: 540-665-8101
sales@reimersinc.com**NAMEPLATE RATINGS:**PART NUMBER RBH30E1FMODEL RH-30

POWER SUPPLY WIRE SIZE _____

POWER VOLTS 240CONTROL VOLT 120PHASE 1HZ 60MAX. W.P. 100KILOWATTS 30**CERTIFICATION & REPORTING (CG-500) CSD-1
OPERATIONAL TEST/ELECTRIC AND STEAM**DATE (M/D/Y) 6 / 29 / 20 15UL FILE # E39545WIRING DIAGRAM # 28, 91, 101, 110, 122, 131, 140 REV 5
X 160, 170, 180**DIELECTRIC VOLTAGE- WITHSTAND**

TEST: (IAW U.L. 834)

VOLTS 1200 SAT ☒ UNSAT _____PERFORMED BY OC DATE 6/29/15**HYDRO TEST OF
COMPLETE BOILER**P.S.I.G. 100PERFORMED BY OCDATE 6/29/15**HEATING ELEMENT TEST**VOLTS 240AMPS 120.3TOTAL WATT 30K**CHECKOUT**

1. APPEARANCE ☒
2. BLOWDOWN MAN _____ AUTO ☒
3. TRANSFORMER _____
4. CONDENSATE TANK _____
5. CONTROLS ☒
6. FEED WATER VALVES ☒
7. INSTRUCTION MANUAL ☒
8. LEAK INSPECTION ☒
9. PAINT ☒
10. PANEL ☒
11. PIPES ☒
12. SHEET METAL ☒
13. STEAM VALVE ☒
14. STEAM GAUGE ☒
15. STRAINER ☒
16. CHECK TORQUE ON TERMINAL STRIPS,
CONTACTORS AND FUSE BLOCKS ☒
17. WARNING LABELS ☒
18. WATER GAUGE FITTINGS ☒
19. WIRE TERMINALS TIGHT ☒
20. WIRING DIA. ☒
21. ELEMENT QTY. 2
22. ELEMENT VOLT/KW 240 15
23. NAMEPLATE ☒
24. JURISDICTION = VA
25. FUEL = ELECTRIC

SAFETY LIMIT CONTROLS (REF: ASME CSD-1, CG-500)**SAFETY RELIEF VALVE**OPERATIONAL TEST PERFORMED OCDATE 6/29/15MANUFACTURER CONBRACOModel # 29-202A-100**STEAM BOILER** ☒**HOT WATER BOILER** ☐MAX. W. P. 100 PSIG (VALVE ASME PLATE)

MAX. W. P. _____ PSIG (VALVE ASME PLATE)

CAPACITY 423 PPH (VALVE ASME PLATE)

CAPACITY _____ BTU/HR (VALVE ASME PLATE)

SIZE 1/2 IN

SIZE _____ IN

REQUIRED CAPACITY (PPH = 3.5 x kW) 105 PPH

REQUIRED CAPACITY (BTU/HR = 3412 x kW) _____ BTU/HR

MAX. TEMPERATURE _____ °F

	OPERATIONAL TEST	SETTING				
LOW WATER CUTOFF	PERFORMED BY	PSI/°F	DATE	MANUFACTURER	MODEL #	PART#
AUTO RESET	N/A	X				
MANUAL RESET	<u>OC</u>	X	<u>6/29/15</u>	REIMERS	04316	04316
PRESSURE CONTROLS						
HIGH LIMIT	<u>OC</u>	90	<u>6/29/15</u>	TECMARK	3155-ED	04296
OPERATING #1	<u>OC</u>	60	<u>6/29/15</u>	TECMARK	3156-EC	04163
OPERATING #2	<u>DC</u>	15	<u>6/29/15</u>	TECMARK	3156-EC	04163
TEMPERATURE CONTROLS						
HIGH LIMIT	N/A					
OPERATING CONTROL						

Representing Reimers Electra Steam, INC. (Name) David E. CoffDATE 6/29/15Signature David E. Coff

Representing Installer Contractor (Name) _____

DATE _____

Signature _____



0031682

Page: 1

Work Order Traveler

SCHEDULED START: 06/23/15

0031682

DUE DATE: 06/25/15

ITEM NUMBER: **RBH30E1F**QUANTITY: **1.00**DESCRIPTION: **BOILER RBH 30KW 240V 1PH 100#**

UNIT OF MEASUREMENT: EA

REVISION: 003

OPTION CODE:

MAKE FOR: I/M

PLANNER:

QTY	PART	DESCRIPTION	QTY	PART	DESCRIPTION
1	04701	CARTON RB 30W 35L 28.75H SLOT	1	02637	VALVE SAFETY .5" 100# SWP 1" O
1	02254	CONNECTOR .375" 2 SCREW NEER	10	04440	WIRE #8 PTFE INS. W/GLASS SLEE
2	02530	CONTACTOR 50A 120V 3P UL/CSA	2	04789	WIRE SADDLE NYLON LOCKING
1	20838	CONTROLLER 04316-EBC-LED			
1	04781	COUPLING .5" BRASS B16.15 125			
1	20775-11	COVER ELEMENT TERMINALS RB REV			
1	20775-7	COVER RIGHT ELEC BOX RB REV3			
1	04229	DECAL SHEET			OPT1008
1	04813	DINCONNECTOR/CORD FOR RB BOILE			OPT1016
1	20848	DISC, ORF-30 30KW STEAM ORIFIC			
1	03923	ELBOW .5" TUBE X .375" NPT SB			
2	04253	ELEMENT 240V 15KW 3PH B-DIM=18			
-2	20598	FLANGE BLIND 2.5" SQ. 4 BOLT			
1	02655	FUSE 250V 5A UL/CSA			
6	04705	FUSE 300V 50A CLASS T UL			
2	04704	FUSE BLOCK 300V 60A 3P UL/CSA			
-2	02281-TOPOG	E GASKET 2.5" X .125" t TOPOG-E			
1	20862	LABEL MAX. TORQUE 40. LB IN /0			
1	20860	LABEL MAX. TORQUE 7.0 LB IN /0			
1	04301	LABEL NAMEPLATE UL/CSA 3.48 X			
2	03077	LOCKWASHER .25" STEEL HELICAL			
1	20840	MANIFOLD FEED WATER SUBASSY RB			
1	04668	NIPPLE .25" X 1.125" BRASS SCH			
1	04787	NUT .25-20 WING ZINC PLATED			
2	01351	NUT .25-20HEX JAM PLATE			
1	20775-13	POWER CABINET FOR 2-PH RB BOIL			
1	04163	PRESSURE CONTROL 60# OPERATING			
1	04296	PRESSURE CONTROL 90# HI LIMIT			
1	20842	PRESSURE CONTROL MANIFOLD RB R			
1	04661	PRESSURE GAUGE 2.0" .25" 0-160			
1	20775-9	PUMP BASE MOUNTING BRACKET			
1	20992	PUMP SUBASSY 03693 120V 1 PH			
1	04593	SCREW .25-20 X .75 HEX CAP PLA			
1	04760	SCREW 1/4"-20 X .75" PAN HEAD			
8	01291	SCREW 8-32X.25RNDHD SLT MCH ZI			
6	01246	SCREW 8-32X.375RDHD MCH PLT SL			
1	04731	STUD PRESS-IN THREADED .25"-20			
1	RB30-SUBASSY	SUBASSEMBLY RB 10 THRU 30 BOIL			
6	04080	TERMINAL RING FOR # 8 AWG WIR			
1	03818	TICKET HOLDER FOR SHOP CLEAR F			
1	02490	VALVE BALL .5" 200# SWP			
1	03346	VALVE BALL .5" W/LATCH 200 SWP			